



## COMMERCIAL HVAC INCENTIVE APPLICATION

Incentive applications will only be processed if fully completed and signed. By signing below, customer and contractor agree to having met the Terms and Conditions. Once completed, return to your electric utility provider.

1. **Customer Name:** \_\_\_\_\_ Electric Utility: \_\_\_\_\_

Customer's Account #: \_\_\_\_\_ Tax ID #: \_\_\_\_\_

Customer's Mailing Address: \_\_\_\_\_ Telephone #: \_\_\_\_\_

Installation Address & City (if different from above): \_\_\_\_\_

Customer: \_\_\_\_\_

Print Name

Signature

Date

2. **Contractor Name:** \_\_\_\_\_

Address: \_\_\_\_\_

Telephone #: \_\_\_\_\_

Fax # \_\_\_\_\_ E-mail: \_\_\_\_\_

Contractor: \_\_\_\_\_

Print Name

Signature

Date

### TERMS & CONDITIONS

This incentive program applies to split system or package air-conditioners, air source heat pumps, water source heat pumps (boiler/cooling tower), and ground source heat pumps less than 20 tons installed in new or existing nonresidential and master-metered multifamily buildings.

**PROOF OF PURCHASE: Sales receipt(s) or invoice(s) itemizing the new equipment and indicating the size, type, make, model, purchase date, and AHRI Certificate of Product Ratings must be submitted, along with the completed application, to the electric utility after installation is complete.**

**INCENTIVE OFFER:** Incentive applications must be submitted within three (3) months of equipment startup. Details of this program, including incentive levels, are subject to change without notice. The electric utility reserves the right to limit incentives.

**ELIGIBLE EQUIPMENT:** Equipment must be new, permanently installed, and operational at the customer's facility. Equipment must meet the minimum efficiency levels as shown in Table 1, and must be rated at the most recent AHRI standards. Prior to submittal of application, the following must be completed on all equipment: air and water balancing, installation and calibration of control system, and training of customer's maintenance personnel.

**ISSUING INCENTIVES:** Equipment must be purchased and installed before an incentive is issued. Falsifying any information may lead to cancellation of this and future incentive applications, a claim by the electric utility for the return of any incentives, and/or referral for prosecution. Please allow 45 days for delivery of incentives.

**APPROVAL & VERIFICATION:** Incentive applications greater than \$5,000 must be pre-approved by the electric utility to guarantee availability of funds. The electric utility reserves the right to verify equipment specifications and review the installation.

**TAX LIABILITY:** Neither the electric utility nor Nebraska Public Power District are responsible for any tax liability imposed on the customer as a result of the energy efficiency incentive.

**ENDORSEMENT:** Neither the electric utility nor Nebraska Public Power District endorses any particular manufacturers, products, nor system designs in promoting this program.

**DISPOSAL:** The customer/contractor is responsible for the proper disposal and/or recycling of any waste generated as a result of this project.

**CODES AND STANDARDS:** The customer/contractor agrees that the installation complies with all applicable federal, state, and local codes. All products must be installed per manufacturer's instructions.

**DISCLAIMER OF WARRANTIES/GUARANTEES:** Neither the electric utility nor Nebraska Public Power District warrant the installation or performance of any equipment either expressly or implicitly. Contact the supplier or contractor for details regarding equipment warranties. The electric utility and Nebraska Public Power District do not guarantee the cost savings or reduction in energy consumption.

**Table 1 - Eligible Equipment**

Unit Code <sup>1</sup>	Equipment Type and Size (tons) <sup>2,3</sup> (Split or Package)	Minimum Cooling Efficiency <sup>4</sup>	Minimum Heating Efficiency <sup>4</sup>	(D) \$ Multiplier	(E) Baseline EER	Incentive
AC1	Air Conditioner (air cooled) < 5.4	14.0 SEER	n/a	n/a	n/a	\$100
AC2	Air Conditioner (air cooled) < 5.4	15.0 SEER	n/a	n/a	n/a	\$125
AC3	Air Conditioner (air cooled) < 5.4	16.0 SEER	n/a	n/a	n/a	\$150
AC4	Air Conditioner (air cooled) ≥ 5.4 to < 11.3	11.3	n/a	20	10.3	\$20 x (Actual EER – 10.3) x tons
AC5	Air Conditioner (air cooled) ≥ 11.3 to < 20	11.1	n/a	20	9.7	\$20 x (Actual EER – 9.7) x tons
AW1	Air Conditioner (water cooled) < 5.4	12.6	n/a	20	10	\$20 x (Actual EER – 10) x tons
AW2	Air Cond. (water cooled) ≥ 5.4 to < 11.3	12.1	n/a	20	10	\$20 x (Actual EER – 10) x tons
AW3	Air Cond. (water cooled) ≥ 11.3 to < 20	11.6	n/a	20	10	\$20 x (Actual EER – 10) x tons
AS1	Air Source Heat Pump < 5.4	14.0 SEER	8.2 HSPF	n/a	n/a	\$200
AS2	Air Source Heat Pump < 5.4	15.0 SEER	8.2 HSPF	n/a	n/a	\$250
AS3	Air Source Heat Pump < 5.4	16.0 SEER	8.2 HSPF	n/a	n/a	\$300
AS4	Air Source Heat Pump ≥ 5.4 to < 11.3	11.0	3.3 @ 47°F	25	10.1	\$25 x (Actual EER – 10.1) x tons
AS5	Air Source Heat Pump ≥ 11.3 to < 20	11.0	3.2 @ 47°F	25	9.3	\$25 x (Actual EER – 9.3) x tons
WLHP1	Water Source Heat Pump < 1.4	11.2 @ 86°F	4.2 @ 68°F	25	10.5	\$25 x (Actual EER – 10.5) x tons
WLHP2	Water Source Heat Pump ≥ 1.4 to < 20	12.0 @ 86°F	4.2 @ 68°F	25	10.5	\$25 x (Actual EER – 10.5) x tons
GWHP	Open Loop Ground Source Heat Pump ≤ 20	16.2 @ 59°F	3.6 @ 50°F	10	16	[\$10 x (Actual EER – 16) + 180] x tons
GLHP	Closed Loop Ground Source Heat Pump ≤ 20	13.4 @ 77°F	3.1 @ 32°F	20	14	[\$20 x (Actual EER – 14) + 180] x tons

<sup>1</sup> WLHP – Water Loop Heat Pump (typically boiler/cooling tower applications); GWHP – Ground Water Heat Pump (typically open loop/pump and dump); GLHP – Ground Loop Heat Pump (typically earth or pond coupled)

<sup>2</sup> Incentives may be available for equipment greater than 20 tons under a custom program.

<sup>3</sup> Table implies new matched indoor and outdoor components. If different, contact your electric utility.

<sup>4</sup> Equipment efficiencies to be rated at full load according to test procedures and conditions specified in ASHRAE Standard 90.1. Unless noted otherwise, all cooling ratings are EERs, and all heating ratings are C.O.P.s.

**Installing Contractor: Complete the following information, using data from the equipment installed, and columns (D) and (E) from Table 1 above. Some example entries are shown.**

Use this table for all equipment codes except GWHP and GLHP:

Unit Code	(A) Qty	Manufacturer & Model No.	(B) Size (Tons)	(C) Cooling Effic.*	Heating Effic.*	(D) \$ Multiplier per Table 1	(E) Baseline per Table 1	Incentive D x (C – E) x B x A (if applicable)
AC5	3	A/C Mfg 48DX015	15	12.0 EER	n/a	20	9.7	\$20 x (12 - 9.7) x 15 x 3 = \$2070
AS2	2	ABC Mfr TWA042, TTC042	3.5	15 SEER	9.0 HSPF	n/a	n/a	2 x \$250 = \$500

Use this table for equipment codes GWHP and GLHP:

Unit Code	(A) Qty	Manufacturer & Model No.	(B) Size (Tons)	(C) Cooling Effic.*	Heating Effic.*	(D) \$ Multiplier per Table 1	(E) Baseline per Table 1	Incentive [D x (C – E) + 180] x B x A
GLHP	1	HTPUMPSRUS P048B225	4	17.0	3.6	20	14	[\$20 x (17 - 14) + 180] x 4 x 1 = \$960

\*Cooling Efficiency and Heating Efficiency must be listed at the temperature rating condition shown in Table 1.